

### Over current switch, 8A, 1p, C-Char, AC

Part no. FAZ-C8/1 Article no. 278556 Catalog No. FAZ-C8/1



Similar to illustration

110	INCEN	DEOC	rommo
	IIVEIV		
-		PIUM	ramme

		Miniature circuit breakers
		1 pole
		C
		Switchgear for industrial and advanced commercial applications
In	Α	8
	kA	15
		FAZ
	I <sub>n</sub>	"

## **Technical data**

### **Electrical**

Standards			IEC/EN 60947-2 IEC/EN 60898
Rated operational voltage	U <sub>e</sub>	V	
	U <sub>e</sub>	V AC	230/400
		V DC	48 (per pole)
Rated switching capacity acc. to IEC/EN 60947-2		kA	15
Operational switching capacity		kA	7.5
Characteristic			B, C, D
Max. back-up fuse		A gL/gG	125
Selectivity Class			3
Lifespan	Operations		> 10000
Direction of incoming supply			as required
Mechanical			
Standard front dimension		mm	45

Wechanical		
Standard front dimension	mm	mm 45
Enclosure height	mm	mm 80
Terminal protection		Finger and back-of-hand proof to BGV A2
Mounting width per pole	mm	mm 17.5
Mounting		IEC/EN 60715 top-hat rail
Degree of Protection		IP20, IP40 (when fitted)
Terminals top and bottom		Twin-purpose terminals
Terminal capacities	mm	mm <sup>2</sup>
	mm	mm <sup>2</sup> 1 x 25
	mm	mm <sup>2</sup> 2 x 10
Thickness of busbar material	mm	mm 0.8 2
Mounting position		As required

# Design verification as per IEC/EN 61439

Technical data for design verification			
Rated operational current for specified heat dissipation	In	Α	8
Heat dissipation per pole, current-dependent	P <sub>vid</sub>	W	0
Equipment heat dissipation, current-dependent	P <sub>vid</sub>	W	2.1
Static heat dissipation, non-current-dependent	P <sub>vs</sub>	W	0

For Sales and Support call KMParts.com (866) 595-9616

Heat dissipation capacity	$P_{\text{diss}}$	W	0
Operating ambient temperature min.		°C	-40
Operating ambient temperature max.		°C	75
			linear, per +1 °C, results in a 0.5% reduction of current carrying capacity
EC/EN 61439 design verification			
10.2 Strength of materials and parts			
10.2.2 Corrosion resistance			Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures			Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat			Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects $$			Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation			Meets the product standard's requirements.
10.2.5 Lifting			Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact			Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions			Meets the product standard's requirements.
10.3 Degree of protection of ASSEMBLIES			Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances			Meets the product standard's requirements.
10.5 Protection against electric shock			Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components			Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections			Is the panel builder's responsibility.
10.8 Connections for external conductors			Is the panel builder's responsibility.
10.9 Insulation properties			
10.9.2 Power-frequency electric strength			Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage			Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material			Is the panel builder's responsibility.
10.10 Temperature rise			The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 Short-circuit rating			Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 Electromagnetic compatibility			Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 Mechanical function			The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

### **Technical data ETIM 6.0**


Circuit breakers and fuses (EG000020) / Miniature circuit breaker (MCB) (EC000042)


Electric engineering, automation, process control engineering / Electrical installation, device / Miniature circuit breaker system (MCB) / Miniature circuit breaker (MCB) (ecl@ss8.1-27-14-19-01 [AAB905011])


Release characteristic			С	
			1	
Number of poles (total)			I	
Number of protected poles			1	
Nominal rated current	Α		8	
Nominal rated voltage	V		230	
Rated short-circuit breaking capacity Icn EN 60898 at 230 V	kΔ	A	10	
Rated short-circuit breaking capacity Icn EN 60898 at 400 V	kΑ	4	10	
Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V	kΑ	4	15	
Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V	kΑ	4	15	
Voltage type			AC	
Current limiting class			3	
Frequency	Hz	Z	50 - 60	
Concurrently switching N-neutral			No	
Suitable for flush-mounted installation			No	
Over voltage category			3	
Pollution degree			2	
Width in number of modular spacings			1	
Built-in depth	mı	m	70.5	
Additional equipment possible			Yes	
Degree of protection (IP)  For Colon and Cupperts and IVMDerts are 1920				
For Sales and Support call KMParts.com (866) 595-9616				


Approvals	
Product Standards	IEC/EN 60947-2; IEC/EN 60898; UL 1077; CSA-C22.2 No. 235; CE marking
UL File No.	E177451
UL Category Control No.	QVNU2, QVNU8
CSA File No.	204453
CSA Class No.	3215-30
North America Certification	UL recognized, CSA certified
Conditions of Acceptability	Supplementary Protector only
Suitable for	Branch Circuits; not as BCPD
Current Limiting Circuit-Breaker	No
Max. Voltage Rating	277 VAC; 48 VDC
Degree of Protection	IEC: IP20; UL/CSA Type: -


# **Characteristics**











# **Dimensions** 8 17.5 44

60

# **Additional product information (links)**

AWA1220-1755 Circiut-breaker

AWA1220-1755 Circiut-breaker ftp://ftp.moeller.net/DOCUMENTATION/AWA\_INSTRUCTIONS/17550701.pdf