



FAZ-D4/1N 278689 FAZ-D4/1N



Similar to illustration

| elivery program | | | |
|--|-------------------|----------|--|
| asic function | | | Miniature circuit breakers |
| umber of poles | | | 1 pole+N |
| ipping characteristic | | | D |
| pplication | | | Switchgear for industrial and advanced commercial applications |
| ated current | l _n | А | 4 |
| ated switching capacity acc. to IEC/EN 60947-2 | | kA | 15 |
| roduct range | | | FAZ |
| | | | |
| echnical data lectrical | | | |
| ated switching capacity acc. to IEC/EN 60947-2 | | kA | 15 |
| | | | |
| esign verification as per IEC/EN 61439 | | | |
| echnical data for design verification | | | |
| Rated operational current for specified heat dissipation | I _n | A | 4 |
| Heat dissipation per pole, current-dependent | P _{vid} | w | 0 |
| Equipment heat dissipation, current-dependent | P _{vid} | W | 1.6 |
| Static heat dissipation, non-current-dependent | P _{vs} | W | 0 |
| | | W | 0 |
| Heat dissipation capacity | P _{diss} | | |
| Operating ambient temperature min. | | °C °C | -40 |
| Operating ambient temperature max. | | °υ | |
| C/EN 61439 design verification | | | linear, per +1 °C, results in a 0.5% reduction of current carrying capacity |
| 10.2 Strength of materials and parts | | | |
| 10.2.2 Corrosion resistance | | | Meats the product standard's requirements |
| 10.2.3.1 Verification of thermal stability of enclosures | | | Meets the product standard's requirements. Meets the product standard's requirements. |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat | | | Meets the product standard's requirements. |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat | | | Meets the product standard's requirements. |
| and fire due to internal electric effects | | | |
| 10.2.4 Resistance to ultra-violet (UV) radiation | | | Meets the product standard's requirements. |
| 10.2.5 Lifting | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 Mechanical impact | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 Inscriptions | | | Meets the product standard's requirements. |
| 10.3 Degree of protection of ASSEMBLIES | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 Clearances and creepage distances | | | Meets the product standard's requirements. |
| 10.5 Protection against electric shock | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 Incorporation of switching devices and components | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 Internal electrical circuits and connections | | | Is the panel builder's responsibility. |
| יט.י התפווומו פופטווטמו טווטעונג מווע טטווופטנוטווג | | | Is the panel builder's responsibility. |
| 10.8 Connections for external conductors | | | |
| | | | |
| 10.8 Connections for external conductors | | | Is the panel builder's responsibility. |
| 10.8 Connections for external conductors 10.9 Insulation properties | | | Is the panel builder's responsibility. Is the panel builder's responsibility. |
| 10.8 Connections for external conductors 10.9 Insulation properties 10.9.2 Power-frequency electric strength | | | |

| 10.11 Short-circuit rating | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
|-------------------------------------|--|
| 10.12 Electromagnetic compatibility | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.13 Mechanical function | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |

Technical data ETIM 6.0

Circuit breakers and fuses (EG000020) / Miniature circuit breaker (MCB) (EC000042)

| | =/ | |
|---|----------------------------|--|
| Electric engineering, automation, process control engineering / Electrical installat [AAB905011]) | tion, device / Miniature c | ircuit breaker system (MCB) / Miniature circuit breaker (MCB) (ecl@ss8.1-27-14-19-01 |
| Release characteristic | | D |
| Number of poles (total) | | 2 |
| Number of protected poles | | 2 |
| Nominal rated current | А | 4 |
| Nominal rated voltage | V | 230 |
| Rated short-circuit breaking capacity Icn EN 60898 at 230 V | kA | 10 |
| Rated short-circuit breaking capacity Icn EN 60898 at 400 V | kA | 10 |
| Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V | kA | 15 |
| Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V | kA | 15 |
| Voltage type | | AC |
| Current limiting class | | 3 |
| Frequency | Hz | 50 - 60 |
| Concurrently switching N-neutral | | Yes |
| Suitable for flush-mounted installation | | No |
| Over voltage category | | 3 |
| Pollution degree | | 2 |
| Width in number of modular spacings | | 2 |
| Built-in depth | mm | 70.5 |
| Additional equipment possible | | Yes |
| Degree of protection (IP) | | IP20 |