DATASHEET - NZM2-XKAM



Tunnel terminal, 3p, 6x35mm², +cover

Part no. NZM2-XKAM

144113

EL Number

4315531

(Norway)

| (Norway) | | |
|--|----------|--|
| General specifications | | |
| Product name | E | Eaton Moeller series NZM connection type |
| Part no. | 1 | NZM2-XKAM |
| EAN | 4 | 4015081406296 |
| Product Length/Depth | 8 | 81 millimetre |
| Product height | 8 | 87 millimetre |
| Product width | 1 | 105 millimetre |
| Product weight | C | 0.42 kilogram |
| Compliances | l | RoHS conform UL/CSA IEC |
| Product Tradename | 1 | NZM |
| Product Type | , and a | Accessories |
| Product Sub Type | (| Connection type |
| Delivery program | | |
| Туре | Į. | Accessory Terminal Tunnel terminal |
| Number of poles | 1 | Three-pole |
| Amperage Rating | <u> </u> | ≦ 250 A |
| Frame | 1 | NZM2 |
| Suitable for | | Copper cable Three-pole |
| Used with | 1 | NZM2, PN2, N(S)2 |
| Technical Data - Mechanical - Terminals | | |
| Terminal capacity (stranded cable) | | 2.5 mm² - 35 mm² (6x) at digital input of supply connection 14 - 2 AWG/kcmil (6x) |
| Design verification as per IEC/EN 61439 | | |
| 10.2.2 Corrosion resistance | 1 | Meets the product standard's requirements. |
| 10.2.3.1 Verification of thermal stability of enclosures | r | Meets the product standard's requirements. |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat | 1 | Meets the product standard's requirements. |
| 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects | 1 | Meets the product standard's requirements. |
| 10.2.4 Resistance to ultra-violet (UV) radiation | 1 | Meets the product standard's requirements. |
| 10.2.5 Lifting | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 Mechanical impact | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 Inscriptions | 1 | Meets the product standard's requirements. |
| 10.3 Degree of protection of assemblies | [| Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 Clearances and creepage distances | 1 | Meets the product standard's requirements. |
| 10.5 Protection against electric shock | [| Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 Incorporation of switching devices and components | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 Internal electrical circuits and connections | I | Is the panel builder's responsibility. |
| 10.8 Connections for external conductors | I | ls the panel builder's responsibility. |
| 10.9.2 Power-frequency electric strength | I | ls the panel builder's responsibility. |
| 10.9.3 Impulse withstand voltage | I | Is the panel builder's responsibility. |
| 10.9.4 Testing of enclosures made of insulating material | I | Is the panel builder's responsibility. |
| 10.10 Temperature rise | ţ | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating | | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.12 Electromagnetic compatibility | | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.13 Mechanical function | | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |

| Additional information | |
|------------------------|-------|
| Model | Other |

Technical data ETIM 9.0

| Low-voltage industrial components (EG000017) / Wiring set for power circuit breaker (EC002050) | | | |
|---|-------|--|--|
| Electric engineering, automation, process control engineering / Low-voltage switch technology / Circuit breaker (LV < 1 kV) / Wiring set for circuit breaker (ecl@ss13-27-37-04-24 [ACN957016]) | | | |
| Suitable for number of poles | 3 | | |
| Model | Other | | |