



Cover, 3p, for screw connection, size 2

Part no. NZM2-XKSA
260038
EL Number 4358780
(Norway)

| | | |
|--|--|---|
| General specifications | | |
| Product name | | Eaton Moeller series NZM connection type |
| Part no. | | NZM2-XKSA |
| EAN | | 4015082600389 |
| Product Length/Depth | | 76 millimetre |
| Product height | | 85 millimetre |
| Product width | | 102 millimetre |
| Product weight | | 0.234 kilogram |
| Compliances | | IEC RoHS conform UL/CSA |
| Certifications | | CSA certified UL (Category Control Number DIHS) CSA (Class No. 1432-01) UL listed CSA (File No. 22086) UL489 IEC60947 CSA-C22.2 No. 5-09 CE marking UL (File No. E31593) |
| Product Tradename | | NZM |
| Product Type | | Accessories |
| Product Sub Type | | Connection type |
| Delivery program | | |
| Type | | Terminal cover Accessory |
| Number of poles | | Three-pole |
| Frame | | NZM2 |
| Used with | | DS7-34...SX135... DS7-34...SX160... NZM2, PN2, NS2 DS7-34...SX200... |
| Design verification as per IEC/EN 61439 | | |
| 10.2.2 Corrosion resistance | | Meets the product standard's requirements. |
| 10.2.3.1 Verification of thermal stability of enclosures | | Meets the product standard's requirements. |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat | | Meets the product standard's requirements. |
| 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects | | Meets the product standard's requirements. |
| 10.2.4 Resistance to ultra-violet (UV) radiation | | Meets the product standard's requirements. |
| 10.2.5 Lifting | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 Mechanical impact | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 Inscriptions | | Meets the product standard's requirements. |
| 10.3 Degree of protection of assemblies | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 Clearances and creepage distances | | Meets the product standard's requirements. |
| 10.5 Protection against electric shock | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 Incorporation of switching devices and components | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 Internal electrical circuits and connections | | Is the panel builder's responsibility. |
| 10.8 Connections for external conductors | | Is the panel builder's responsibility. |
| 10.9.2 Power-frequency electric strength | | Is the panel builder's responsibility. |
| 10.9.3 Impulse withstand voltage | | Is the panel builder's responsibility. |
| 10.9.4 Testing of enclosures made of insulating material | | Is the panel builder's responsibility. |
| 10.10 Temperature rise | | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating | | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |

| | | | |
|-------------------------------------|--|--|--|
| 10.12 Electromagnetic compatibility | | | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.13 Mechanical function | | | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |
| Additional information | | | |
| Phase separator type | | | Other |

Technical data ETIM 9.0

| | | | |
|---|--|--|-------|
| Low-voltage industrial components (EG000017) / Phase separation plate for power circuit breaker (EC002035) | | | |
| Electric engineering, automation, process control engineering / Low-voltage switch technology / Circuit breaker (LV < 1 kV) / Phase separation plate for circuit breaker (ecl@ss13-27-37-04-25 [ACN959016]) | | | |
| Model | | | Other |