## **DATASHEET - PKZM0-XRM12**



### Wiring set, For reversing starters, DILM7-M12

Powering Business Worldwide

Part no. PKZM0-XRM12 Catalog No. 283185 Alternate Catalog XTPAXTPCRB

No

**EL-Nummer** 4365081

(Norway)

## **Delivery program**

| Product range | Accessories                                                              |
|---------------|--------------------------------------------------------------------------|
| Accessories   | Wiring set                                                               |
|               | For reversing starters                                                   |
| For use with  | PKZM0, PKE + DILM7-01<br>PKZM0, PKE + DILM9-01<br>PKZM0, PKE + DILM12-01 |

#### Notes

#### Consists of:

- Mechanical connection element for PKZM0, PKE, and contactor Main current wiring for reversing starter with tool-less plug connection Control cables for electrical interlock with tool-less plug connection:K1M: A1 -K2M: 21K1M: 21 -K2M: A1K1M: A2 -K2M: A2 Cable routing
- Use as auxiliary contact DILA-XHIT...
- Cannot be combined with AGM-PKZ0 or NHI...-PKZ0 for mounting on the side.
- U<sub>e</sub> ≤ 415 V

## **Design verification as per IEC/EN 61439**

| In                | Α                                                                   | 15.5                                                                                                                             |
|-------------------|---------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------|
| P <sub>vid</sub>  | W                                                                   | 0.5                                                                                                                              |
| P <sub>vid</sub>  | W                                                                   | 1.5                                                                                                                              |
| P <sub>vs</sub>   | W                                                                   | 0                                                                                                                                |
| P <sub>diss</sub> | W                                                                   | 0                                                                                                                                |
|                   | °C                                                                  | -25                                                                                                                              |
|                   | °C                                                                  | 55                                                                                                                               |
|                   |                                                                     |                                                                                                                                  |
|                   |                                                                     |                                                                                                                                  |
|                   |                                                                     | Meets the product standard's requirements.                                                                                       |
|                   |                                                                     | Meets the product standard's requirements.                                                                                       |
|                   |                                                                     | Meets the product standard's requirements.                                                                                       |
|                   |                                                                     | Meets the product standard's requirements.                                                                                       |
|                   |                                                                     | Meets the product standard's requirements.                                                                                       |
|                   |                                                                     | Does not apply, since the entire switchgear needs to be evaluated.                                                               |
|                   |                                                                     | Does not apply, since the entire switchgear needs to be evaluated.                                                               |
|                   |                                                                     | Meets the product standard's requirements.                                                                                       |
|                   |                                                                     | Does not apply, since the entire switchgear needs to be evaluated.                                                               |
|                   |                                                                     | Meets the product standard's requirements.                                                                                       |
|                   |                                                                     | Does not apply, since the entire switchgear needs to be evaluated.                                                               |
|                   |                                                                     | Does not apply, since the entire switchgear needs to be evaluated.                                                               |
|                   |                                                                     | Is the panel builder's responsibility.                                                                                           |
|                   |                                                                     | Is the panel builder's responsibility.                                                                                           |
|                   |                                                                     |                                                                                                                                  |
|                   |                                                                     | Is the panel builder's responsibility.                                                                                           |
|                   |                                                                     | Is the panel builder's responsibility.                                                                                           |
|                   |                                                                     | Is the panel builder's responsibility.                                                                                           |
|                   |                                                                     | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
|                   |                                                                     | Is the panel builder's responsibility. The specifications for the switchgear must b observed.                                    |
|                   | P <sub>vid</sub> P <sub>vid</sub> P <sub>vs</sub> P <sub>diss</sub> | P <sub>vid</sub> W P <sub>vid</sub> W P <sub>vs</sub> W P <sub>diss</sub> W °C °C                                                |

| 10.12 Electromagnetic compatibility | Is the panel builder's responsibility. The specifications for the switchgear must be observed.           |
|-------------------------------------|----------------------------------------------------------------------------------------------------------|
| 10.13 Mechanical function           | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |

## **Technical data ETIM 7.0**

Low-voltage industrial components (EG000017) / Wiring set for power circuit breaker (EC002050)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Circuit breaker (LV < 1 kV) / Wiring set for circuit breaker (ecl@ss10.0.1-27-37-04-24 [ACN957011])

| Suitable for number of poles | 3                   |
|------------------------------|---------------------|
| Model                        | Reversing switching |

# **Approvals**

| Product Standards                    | UL 508; CSA-C22.2 No. 14; IEC60947-4-1; CE marking |
|--------------------------------------|----------------------------------------------------|
| UL File No.                          | E36332                                             |
| UL Category Control No.              | NLRV                                               |
| CSA File No.                         | 165628                                             |
| CSA Class No.                        | 3211-05                                            |
| North America Certification          | UL listed, CSA certified                           |
| Specially designed for North America | No                                                 |