Specifications

Eaton 072898

Eaton Moeller® series PKZ Trip indicator, 2 x 1 N/O, Screw terminals

General specifications	
PRODUCT NAME	Eaton Moeller® series PKZ Trip indicator
CATALOG NUMBER	072898
MODEL CODE	AGM2-10-PKZ0
EAN	4015080728986
PRODUCT LENGTH/DEPTH	68 mm
PRODUCT HEIGHT	90 mm
PRODUCT WIDTH	23 mm
PRODUCT WEIGHT	0.035 kg
CERTIFICATIONS	CSA Class No.: 3211-05 UL File No.: E36332 CE IEC/EN 60947-4-1 UL Category Control No.: NLRV UL CSA-C22.2 No. 14 CSA CSA File No.: 165628 UL 508

Powering Business Worldwide

Features & Functions

ELECTRIC CONNECTION TYPE	Screw connection
INDICATION	Short-circuits indicated locally by means of a red indicator that can be manually reset General trip indication (overload)

General

LIFESPAN, ELECTRICAL	50,000 Operations
LIFESPAN, MECHANICAL	10,000 Operations
MODEL	Top mounting
MOUNTING METHOD	Side mounting
OVERVOLTAGE CATEGORY	III
POLLUTION DEGREE	3
PRODUCT CATEGORY	Accessories
RATED IMPULSE WITHSTAND VOLTAGE (UIMP)	6000 V AC
USED WITH	Motor protective circuit-breaker

Climatic environmental conditions

AMBIENT OPERATING TEMPERATURE - MIN	-25 °C
AMBIENT OPERATING TEMPERATURE - MAX	55 °C

Terminal capacities

TERMINAL CAPACITY (SOLID/FLEXIBLE WITH FERRULE)	0.75 - 2.5 mm^2
TERMINAL CAPACITY (SOLID/STRANDED AWG)	18 - 14

Electrical rating

RATED OPERATIONAL CURRENT (IE)	1 A at AC-15, 440 V 500 V
RATED OPERATIONAL CURRENT (IE) AT AC-15, 220 V, 230 V, 240 V	3.5 A
RATED OPERATIONAL CURRENT (IE) AT AC-15, 380 V, 400 V, 415 V	2 A
RATED OPERATIONAL CURRENT (IE) AT DC-13, 110 V	0.5 A
RATED OPERATIONAL CURRENT (IE) AT DC-13, 220 V, 230 V	0.25 A
RATED OPERATIONAL CURRENT (IE) AT DC-13, 60 V	1 A
RATED OPERATIONAL VOLTAGE (UE) AT DC - MAX	250 V
SAFE ISOLATION	440 V, Between auxiliary contacts and main contacts, According to EN 61140
SAFE ISOLATION	440 V, Between auxiliary contacts and main contacts, According to EN 61140

Short-circuit rating

SHORT-CIRCUIT PROTECTION RATING WITHOUT WELDING	10 A gG/gL, Fuse, Auxiliary contacts

Switching capacity

SWITCHING CAPACITY (AUXILIARY CONTACTS, GENERAL USE)	5 A, 600 V AC, (UL/CSA) 1 A, 250 V DC, (UL/CSA)
SWITCHING CAPACITY (AUXILIARY CONTACTS, PILOT DUTY)	A600, AC operated (UL/CSA) Q300, DC operated (UL/CSA)

Communication

CONNECTION TYPE	Screw connection

Contacts

CONTROL CIRCUIT RELIABILITY	< 2 λ, < 1 failure at 100,000,000 Operations (at U_e = 24 V DC, Umin = 17 V, Imin = 5.4 mA)
NUMBER OF CONTACTS (CHANGE-OVER CONTACTS)	0
NUMBER OF CONTACTS (NORMALLY CLOSED CONTACTS)	0
NUMBER OF CONTACTS (NORMALLY OPEN CONTACTS)	2

Design verification

EQUIPMENT HEAT DISSIPATION, CURRENT-DEPENDENT PVID	0 W
HEAT DISSIPATION CAPACITY PDISS	0 W
HEAT DISSIPATION PER POLE, CURRENT-DEPENDENT PVID	0.1 W
RATED OPERATIONAL CURRENT FOR SPECIFIED HEAT DISSIPATION (IN)	3.5 A
STATIC HEAT DISSIPATION, NON-CURRENT-DEPENDENT PVS	0 W
10.2.2 CORROSION RESISTANCE	Meets the product standard's requirements.
10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES	Meets the product standard's requirements.
10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT	Meets the product standard's requirements.
10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS	Meets the product standard's requirements.
10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION	Meets the product standard's requirements.
10.2.5 LIFTING	Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 MECHANICAL IMPACT	Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 INSCRIPTIONS	Meets the product standard's requirements.
10.3 DEGREE OF PROTECTION OF ASSEMBLIES	Does not apply, since the entire switchgear needs to be evaluated.
10.4 CLEARANCES AND CREEPAGE DISTANCES	Meets the product standard's requirements.
10.5 PROTECTION AGAINST ELECTRIC SHOCK	Does not apply, since the entire switchgear needs to be evaluated.
10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS	Does not apply, since the entire switchgear needs to be evaluated.

10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS	Is the panel builder's responsibility.
10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS	Is the panel builder's responsibility.
10.9.2 POWER-FREQUENCY ELECTRIC STRENGTH	Is the panel builder's responsibility.
10.9.3 IMPULSE WITHSTAND VOLTAGE	Is the panel builder's responsibility.
10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL	Is the panel builder's responsibility.
10.10 TEMPERATURE RISE	The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 SHORT-CIRCUIT RATING	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 ELECTROMAGNETIC COMPATIBILITY	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 MECHANICAL FUNCTION	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

Resources	
BROCHURES	eaton-motor-protective-circuit-breaker-pke-and-communication-modul-pke-brochure-w12107613en-en-us.pdf eaton-motor-starters-system-xstart-brochure-br03407001en-en-us.pdf
CATALOGUES	eaton-product-overview-for-machinery-catalogue-ca08103003zen-en-us.pdf Product Range Catalog Switching and protecting motors
CHARACTERISTIC CURVE	eaton-motorstarters-auxiliary-contact-pkz-trip-indicator-characteristic-curve.eps eaton-motorstarters-auxiliary-contact-pkz-trip-indicator-characteristic-curve-002.eps
DECLARATIONS OF CONFORMITY	eaton-accessory-declaration-of-conformity-eu250671en.pdf eaton-accessory-declaration-of-conformity-uk251154en.pdf
DRAWINGS	eaton-manual-motor-starters-auxiliary-contact-pkz0-trip-indicator-dimensions.eps eaton-manual-motor-starters-auxiliary-contact-pkz-trip-indicator-3d-drawing.eps
ECAD MODEL	ETN.072898.edz
INSTALLATION INSTRUCTIONS	IL03402030Z
INSTALLATION VIDEOS	Video Motor Protective Circuit Breaker PKE WIN-WIN with push-in technology
MCAD MODEL	DA-CS-agm2 DA-CD-agm2
SALES NOTES	eaton-pke-modbus-rtu-modul-flyer-fl034008en-en-us.pdf

WIRING DIAGRAMS	eaton-motorstarters-auxiliary-contact-pkz-trip-indicator-wiring-diagram.eps

PROJECT NAME:	
PROJECT NUMBER:	
PREPARED BY:	
DATE:	

Eaton Corporation plc
Eaton House
30 Pembroke Road
Dublin 4, Ireland
Eaton.com

Follow us on social media to get the latest product and support information.