## Specifications







## Eaton 153164

Eaton Moeller® series PKE Trip block, 15 - 36 A, System protection, Connection to SmartWire-DT: no, For use with: PKE32 basic device

General specifications	
PRODUCT NAME	Eaton Moeller® series PKE Trip block
CATALOG NUMBER	153164
MODEL CODE	PKE-XTUCP-36
EAN	4015081498918
PRODUCT LENGTH/DEPTH	41.6 mm
PRODUCT HEIGHT	64.2 mm
PRODUCT WIDTH	45 mm
PRODUCT WEIGHT	0.09 kg
CERTIFICATIONS	VDE 0660 IEC/EN 60947
CATALOG NOTES	This is a product for Environment A (Industrial). In environment B (household) this device may cause undesirable radio interference. In this case the user may be obliged to take appropriate measures.



Features & Functions	
FUNCTIONS	Short-circuit protection Line and cable protection System protection Overcurrent protection
NUMBER OF POLES	Three-pole

General	
CURRENT FLOW TIMES - MIN	1000 (Class 20) AC-4 cycle operation, Main conducting paths Note: Going below the minimum current flow time can cause overheating of the load (motor). For all combinations with an SWD activation, you need not adhere to the minimum current flow times and minimum cutout periods. 500 (Class 5) AC-4 cycle operation, Main conducting paths 700 (Class 10) AC-4 cycle operation, Main conducting paths 900 (Class 15) AC-4 cycle operation, Main conducting paths
CUT-OUT PERIODS - MIN	≤ 500 ms, main conducting paths, AC-4 cycle operation
	Device: IP20
DEGREE OF PROTECTION	Terminals: IP00
OPERATING FREQUENCY	
	Terminals: IP00
OPERATING FREQUENCY OVERLOAD RELEASE	Terminals: IP00 60 Operations/h
OPERATING FREQUENCY OVERLOAD RELEASE CURRENT SETTING - MIN OVERLOAD RELEASE	Terminals: IP00 60 Operations/h 15 A
OPERATING FREQUENCY  OVERLOAD RELEASE CURRENT SETTING - MIN  OVERLOAD RELEASE CURRENT SETTING - MAX  OVERVOLTAGE	Terminals: IP00 60 Operations/h 15 A 36 A
OPERATING FREQUENCY  OVERLOAD RELEASE CURRENT SETTING - MIN  OVERLOAD RELEASE CURRENT SETTING - MAX  OVERVOLTAGE CATEGORY	Terminals: IP00 60 Operations/h 15 A 36 A
OPERATING FREQUENCY  OVERLOAD RELEASE CURRENT SETTING - MIN  OVERLOAD RELEASE CURRENT SETTING - MAX  OVERVOLTAGE CATEGORY  POLLUTION DEGREE	Terminals: IP00 60 Operations/h 15 A 36 A III
OPERATING FREQUENCY OVERLOAD RELEASE CURRENT SETTING - MIN OVERLOAD RELEASE CURRENT SETTING - MAX OVERVOLTAGE CATEGORY POLLUTION DEGREE PRODUCT CATEGORY	Terminals: IP00  60 Operations/h  15 A  36 A  III  3  Accessories  Finger and back-of-hand proof, Protection against direct contact when actuated from front (EN
OPERATING FREQUENCY  OVERLOAD RELEASE CURRENT SETTING - MIN  OVERLOAD RELEASE CURRENT SETTING - MAX  OVERVOLTAGE CATEGORY  POLLUTION DEGREE  PRODUCT CATEGORY  PROTECTION  RATED IMPULSE WITHSTAND VOLTAGE	Terminals: IP00  60 Operations/h  15 A  36 A  III  3  Accessories  Finger and back-of-hand proof, Protection against direct contact when actuated from front (EN 50274)
OPERATING FREQUENCY  OVERLOAD RELEASE CURRENT SETTING - MIN  OVERLOAD RELEASE CURRENT SETTING - MAX  OVERVOLTAGE CATEGORY  POLLUTION DEGREE  PRODUCT CATEGORY  PROTECTION  RATED IMPULSE WITHSTAND VOLTAGE (UIMP)  TEMPERATURE	Terminals: IP00  60 Operations/h  15 A  36 A  III  3  Accessories  Finger and back-of-hand proof, Protection against direct contact when actuated from front (EN 50274)  6000 V AC  -5 - 40 °C to IEC/EN 60947, VDE 0660 -25 - 55 °C, Operating

Ambient conditions, mechanical	
SHOCK RESISTANCE	25 g, Mechanical, according to IEC/EN 60068-2-27, Half- sinusoidal shock 10 ms

Climatic environmental conditions	
ALTITUDE	Max. 2000 m
AMBIENT OPERATING TEMPERATURE - MIN	-25 °C
AMBIENT OPERATING TEMPERATURE - MAX	55 °C
AMBIENT OPERATING TEMPERATURE (ENCLOSED) - MIN	-25 °C
AMBIENT OPERATING TEMPERATURE (ENCLOSED) - MAX	40 °C
AMBIENT STORAGE TEMPERATURE - MIN	-40 °C
AMBIENT STORAGE TEMPERATURE - MAX	80 °C
CLIMATIC PROOFING	Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78

Electrical rating	
RATED FREQUENCY - MIN	50 Hz
RATED FREQUENCY - MAX	60 Hz
RATED OPERATIONAL CURRENT (IE)	36 A
RATED OPERATIONAL VOLTAGE (UE) AT AC - MAX	690 V
RATED UNINTERRUPTED CURRENT (IU)	36 A
SUPPLY VOLTAGE AT AC, 50 HZ - MIN	690 V
SUPPLY VOLTAGE AT AC, 50 HZ - MAX	690 V

Short-circuit rating	
SHORT-CIRCUIT RELEASE	Delayed approx. 60 ms, Trip blocks 75 A - 288 A, Irm, Setting range ± 20% tolerance, Trip blocks Trip block adjustable 5 - 8 x Ir

Magnet system	
RATED CONTROL SUPPLY VOLTAGE (US) AT AC, 50 HZ - MIN	0 V
RATED CONTROL SUPPLY VOLTAGE (US) AT AC, 50 HZ - MAX	0 V
RATED CONTROL SUPPLY VOLTAGE (US) AT AC, 60 HZ - MIN	0 V
RATED CONTROL SUPPLY VOLTAGE (US) AT AC, 60 HZ - MAX	0 V
RATED CONTROL SUPPLY VOLTAGE (US) AT DC - MIN	0 V
RATED CONTROL SUPPLY VOLTAGE (US) AT DC - MAX	0 V

Communication	
CONNECTION TO SMARTWIRE-DT	No

Contacts	
NUMBER OF AUXILIARY CONTACTS (CHANGE- OVER CONTACTS)	0
NUMBER OF AUXILIARY CONTACTS (NORMALLY CLOSED CONTACTS)	0
NUMBER OF AUXILIARY CONTACTS (NORMALLY OPEN CONTACTS)	0

Design verification	
EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT PVID	4.9 W
HEAT DISSIPATION CAPACITY PDISS	0 W
HEAT DISSIPATION PER POLE, CURRENT- DEPENDENT PVID	1.7 W
RATED OPERATIONAL CURRENT FOR SPECIFIED HEAT DISSIPATION (IN)	36 A
STATIC HEAT DISSIPATION, NON- CURRENT-DEPENDENT PVS	0 W
10.2.2 CORROSION RESISTANCE	Meets the product standard's requirements.
10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES	Meets the product standard's requirements.
10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT	Meets the product standard's requirements.
10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS	Meets the product standard's requirements.
10.2.4 RESISTANCE TO	Meets the product

ULTRA-VIOLET (UV) RADIATION	standard's requirements.
10.2.5 LIFTING	Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 MECHANICAL IMPACT	Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 INSCRIPTIONS	Meets the product standard's requirements.
10.3 DEGREE OF PROTECTION OF ASSEMBLIES	Does not apply, since the entire switchgear needs to be evaluated.
10.4 CLEARANCES AND CREEPAGE DISTANCES	Meets the product standard's requirements.
10.5 PROTECTION AGAINST ELECTRIC SHOCK	Does not apply, since the entire switchgear needs to be evaluated.
10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS	Does not apply, since the entire switchgear needs to be evaluated.
10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS	ls the panel builder's responsibility.
10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS	ls the panel builder's responsibility.
10.9.2 POWER- FREQUENCY ELECTRIC STRENGTH	ls the panel builder's responsibility.
10.9.3 IMPULSE WITHSTAND VOLTAGE	ls the panel builder's responsibility.
10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL	ls the panel builder's responsibility.
10.10 TEMPERATURE RISE	The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 SHORT-CIRCUIT RATING	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 ELECTROMAGNETIC COMPATIBILITY	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 MECHANICAL FUNCTION	The device meets the requirements, provided the information in the

instruction leaflet (IL) is observed.

Resources	
BROCHURES	eaton-motor-starters- system-xstart-brochure- br03407001en-en-us.pdf
	eaton-motor-protective- circuit-breaker-pke-and- communication-modul- pke-brochure- w12107613en-en-us.pdf
CATALOGUES	Product Range Catalog Switching and protecting motors
	eaton-product-overview- for-machinery-catalogue- ca08103003zen-en-us.pdf
DECLARATIONS OF CONFORMITY	eaton-accessory- declaration-of-conformity- eu250706en.pdf
	eaton-accessory- declaration-of-conformity- uk251189en.pdf
DRAWINGS	eaton-manual-motor- starters-pke-trip-block- characteristic-curve-002- de.eps
	eaton-manual-motor- starters-mounting-3d- drawing.eps
	eaton-manual-motor- starters-pke-trip-block-3d- drawing-002.eps
ECAD MODEL	ETN.153164.edz
INSTALLATION INSTRUCTIONS	<u>IL034013ZU</u>
INSTALLATION VIDEOS	<u>Video Motor Protective</u> <u>Circuit Breaker PKE</u>
	WIN-WIN with push-in technology
MANUALS AND USER GUIDES	eaton-motor-protection- pke12-32-65- mn03402004z-de-de-en- us.pdf
MCAD MODEL	DA-CS-pke_xtu12  DA-CD-pke_xtu12
SALES NOTES	eaton-pke-modbus-rtu- modul-flyer-fl034008en- en-us.pdf

PROJECT NAME:	
PROJECT NUMBER:	
PREPARED BY:	
DATE:	



**Eaton Corporation plc** Eaton House 30 Pembroke Road Dublin 4, Ireland Eaton.com

© 2025 Eaton. All Rights Reserved.

Follow us on social media to get the latest product and support information.









